

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse SideState of Texas
WELL REPORTTexas Water Well Drillers Advisory Council
P.O. Box 13087
Austin, TX 78711-3087
512-239-0530

1) OWNER Ellis Unit ADDRESS FM 980 Huntsville Tx 77340
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: Estelle Unit Huntsville Tx GRID # 60-05-7
County Walker (Street, RFD or other) (City) (State) (Zip)

3) TYPE OF WORK (Check):
☒ New Well ☐ Deepening
☐ Reconditioning ☐ Plugging

4) PROPOSED USE (Check): ☐ Monitor ☐ Environmental Soil Boring ☐ Domestic
☐ Industrial ☐ Irrigation ☐ Injection ☐ Public Supply ☐ De-watering ☐ Testwell
If Public Supply well, were plans submitted to the TNRCC? ☐ Yes ☐ No

5)

6) WELL LOG:

Date Drilling:

Started 6-23 19 97Completed 6-25 19 97

DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
11	Surface	191

7) DRILLING METHOD (Check):

☐ Driven
☐ Air Rotary ☒ Mud Rotary ☐ Bored
☐ Air Hammer ☐ Cable Tool ☐ Jetted
☐ Other _____

N

From (ft.)	To (ft.)	Description and color of formation material
0	2	t.s.
2	12	sd.
12	15	cl.
15	30	sd.
30	42	bl. cl.
42	62	bl. cl. w/ sd. st.
62	79	bl. cl.
79	82	sd. st.
82	102	sd. w/ cl. st.
102	122	bl. cl. w/ lign. st.
122	130	cl.
130	132	r. st.
132	152	bl. cl.
152	155	sd. st.
155	190	sd.
190	191 (Use reverse side if necessary)	cl.

From (ft.)	To (ft.)	Description and color of formation material
0	2	t.s.
2	12	sd.
12	15	cl.
15	30	sd.
30	42	bl. cl.
42	62	bl. cl. w/ sd. st.
62	79	bl. cl.
79	82	sd. st.
82	102	sd. w/ cl. st.
102	122	bl. cl. w/ lign. st.
122	130	cl.
130	132	r. st.
132	152	bl. cl.
152	155	sd. st.
155	190	sd.
190	191 (Use reverse side if necessary)	cl.

8) Borehole Completion (Check):

☐ Open Hole ☐ Straight Wall
☐ Underreamed ☒ Gravel Packed ☐ Other _____
If Gravel Packed give interval ... from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	N	PVC Casing	-4	170	
4	N	PVC Screen	170	190	

9) CEMENTING DATA [Rule 338.44(1)]

Cemented from 0 ft. to 20 ft. No. of sacks used 8
_____ ft. to _____ ft. No. of sacks used _____
Method used from top
Cemented by R. McPike
Distance to septic system field lines or other concentrated contamination _____ ft.
Method of verification of above distance none

13) TYPE PUMP:

☐ Turbine ☐ Jet ☐ Submersible ☐ Cylinder
☐ Other _____
Depth to pump bowls, cylinder, jet, etc., _____ ft.

14) WELL TESTS:

Type test: ☐ Pump ☐ Bailer ☒ Jetted ☒ Estimated
Yield: 70 gpm with _____ ft. drawdown after _____ hrs.

15) WATER QUALITY:

Did you knowingly penetrate any strata which contained undesirable constituents?
☐ Yes ☒ No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? good Depth of strata 45
Was a chemical analysis made? ☐ Yes ☒ No

10) SURFACE COMPLETION

☐ Specified Surface Slab Installed [Rule 338.44(2)(A)]
☐ Specified Steel Sleeve Installed [Rule 338.44(3)(A)]
☐ Pitless Adapter Used [Rule 338.44(3)(b)]
☐ Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL:

Static level 25 ft. below land surface Date _____
Artesian flow _____ gpm. Date _____

12) PACKERS:

Type _____ Depth _____

TEXAS WATER
CONSERVATION COUNCIL

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Holly Water Wells
(Type or print)WELL DRILLER'S LICENSE NO. 3114WADDRESS 607 Hwy 19
(Street or RFD)Huntsville Tx 77340
(City) (State) (Zip)

(Signed)

Raymond McPike
(Licensed Well Driller)

(Signed)

(Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available. 60 05 7

9

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.

[illegible]